

Dear Frank,

I refer to your official information request we received on 23 July 2023 requesting the following:

“Could you please confirm an importance level of 4 was used in this design?”

Release of information

The information you have requested is as below.

Could you please confirm an importance level of 4 was used in this design?

Kaikōura District Council can confirm that an importance level of 3 was used in the design (as per the advice from the architects involved) of the Civic Building located at 96 West End Kaikōura.

Publication of responses to LGOIMA requests

Please note: our LGOIMA responses may be published on the Kaikōura District Council website a month after they have been responded to, with requesters’ personal details withheld. If you have any concerns about this please contact the Official Information team on officialinformation@kaikoura.govt.nz.

We are obliged by the LGOIMA Act to advise you have the right to ask the Ombudsman to investigate and review our decision. Complaints can be sent by email to info@ombudsman.parliament.nz, by fax to (04) 471 2254, or by post to The Ombudsman, PO Box 10152, Wellington 6143.

Kind regards

For and on behalf of
Will Doughty
Chief Executive Officer