

# SMS Incident Report


24/07/2017 14:11:49

## Summary

**CAD Number** F2346657 **Status** Closed  
**Station** Parnell Station  
**Incident Started** 20/07/2017 04:42:10 **Incident Ended** 20/07/2017 05:45:21  
**Incident Type** 1102: Structure fire with no damage  
**Common Name** 118503  
**Address** 40 BEACH ROAD AUCKLAND CENTRAL  
**Alarm Method** Automatic PFA Call **Alarm Level** 1  
**PFA Number** 118503  
**Zone** 142505  
**Map Grid E** 1758128 **Map Grid N** 5920651  
**First Caller** ELECTRA SERVICES LIMITED **First Caller Contact** ██████████  
**Incident Closed** 20/07/2017 06:09:10  
**Report Completed** 19:44, Thur 20 Jul 2017 by Craig Lampp

## Responses

Call Sign	Type	Station Alert	Enroute Time	Arrival Time	Departed
PARN251	P1	04:42:54 20 Jul 2017	04:44:07 20 Jul 2017	04:46:39 20 Jul 2017	05:46:10 20 Jul 2017
AUCK207	PR	04:42:57 20 Jul 2017	04:44:48 20 Jul 2017	04:48:00 20 Jul 2017	05:39:52 20 Jul 2017
PARN255	HPNP	04:52:24 20 Jul 2017	04:53:54 20 Jul 2017	04:57:40 20 Jul 2017	05:29:03 20 Jul 2017
GREY261	P1	04:52:27 20 Jul 2017	04:53:51 20 Jul 2017	05:00:01 20 Jul 2017	05:44:45 20 Jul 2017



## Elapsed Times

Call Sign	Start To Alert	Alert To Arrival	Start To Arrival	Start To Departed
PARN251	00:00:44	00:03:45	00:04:29	01:04:00
AUCK207	00:00:47	00:05:03	00:05:50	00:57:42
PARN255	00:10:14	00:05:16	00:15:30	00:46:53

Caution: The information contained in this report is subject to the provisions of the Official Information Act 1982 and the Privacy Act 1993. Neither the information nor the report should be released to any person outside the NZ Fire Service or the National Rural Fire Authority without prior approval

GREY261	00:10:17	00:07:34	00:17:51	01:02:35
---------	----------	----------	----------	----------

### Notifications

Date	Time	Party Notified
20 Jul 2017	05:25:21	PMC CALLS TO ADVISE OF ANOTHER ACTIVATION

### Message Log

Time	Message
04:42:31	PANEL: MAIN ENTRANCE OFF BEACH RD
04:42:31	INC INFO: ALARM ACTIVATION - COMMERCIAL
04:42:38	** LOI search completed at 20/07/17 04:42:38
04:42:41	** Recommended unit PARN251 for requirement PUMP (>1.0 km)
04:42:41	** Recommended unit AUCK207 for requirement PUMP (>1.7 km)
04:43:43	ACCESS NO:
04:44:08	Unit PARN251 [ K1 : PROCEEDING TO INCIDENT]
04:44:49	Unit AUCK207 [ K1 : PROCEEDING TO INCIDENT]
04:45:41	AL: 118503 04:44:10 INITIAL - AL
04:45:41	End of Duplicate Event data
04:45:41	** Cross Referenced to Event # F2346660 at: 20/07/17 04:45:41
04:45:41	Duplicate Event:Location = 40 BEACH RD AUCKLAND #118503Cross Street 1TANGIHUA
04:45:41	PANEL: MAIN ENTRANCE OFF BEACH RD
04:45:41	STCross Street 2MAHUUH CR, Type = SPRNKLR, Subtype = default, Call Source =
04:45:41	PFAAlarm Level1
04:45:41	** LOI search completed at 20/07/17 04:44:17
04:46:39	Unit PARN251 [ K77 : NOTHING SHOWING]
04:48:01	Unit AUCK207 [ K2 : IN ATTENDANCE AT INCIDENT]
04:49:41	Unit PARN251 [ KC : UNIT CALLING]
04:50:39	Unit PARN251 [ SITREP : ] SO LAMP; PS SMOKE LEVEL 1 RETAIL A INV
04:51:20	Unit PARN251 [ KP : PRIORITY MESSAGE]
04:51:46	Unit PARN251 [ KP : PRIORITY MESSAGE] TXMT 1ST ALARM FIRE ON 1ST FLOOR
04:52:08	INC INFO: TXNT 1ST ALARM, FIRE ON 1ST FLOOR
04:52:08	** Event Type changed from SPRNKLR to STRU at: 20/07/17 04:52:08
04:52:16	** Recommended unit PARN255 for requirement AERIAL (>1.0 km)
04:52:16	** Recommended unit GREY261 for requirement PUMP (>3.6 km)
04:53:51	Unit GREY261 [ K1 : PROCEEDING TO INCIDENT]
04:53:55	Unit PARN255 [ K1 : PROCEEDING TO INCIDENT]
04:57:04	Unit PARN251 [ KC : UNIT CALLING]
04:57:41	Unit PARN255 [ K2 : IN ATTENDANCE AT INCIDENT]
04:57:55	Unit PARN251 [ SITREP : ] SSO DEVOE; FIRE LOCATED ON GR FLOOR IN LAUNDRY. USING

04:57:55	1 HPD AND 1 LPD AS COVER
05:00:02	Unit GREY261 [ K2 : IN ATTENDANCE AT INCIDENT]
05:02:16	Unit PARN251 [ KC : UNIT CALLING]
05:02:43	Unit PARN251 [ SITREP : ] FIRE EXTINGUISHED VENTILATING
05:22:01	Unit AUCK207 [COMCEN COM : MESSAGE] ANOTHER ACTIVATION, SAME PFA NUMBER
05:22:09	** Cross Referenced to Event # F2346665 at: 20/07/17 05:22:09
05:22:09	AL: 118503 05:20:57 INITIAL - AL
05:22:09	Duplicate Event:Location = 40 BEACH RD AUCKLAND #118503Cross Street 1TANGIHUA
05:22:09	End of Duplicate Event data
05:22:09	PANEL: MAIN ENTRANCE OFF BEACH RD
05:22:09	STCross Street 2MAHUHU CR, Type = SPRNKLR, Subtype = default, Call Source =
05:22:09	PFAAlarm Level1
05:22:09	** LOI search completed at 20/07/17 05:21:03
05:23:35	PANEL: MAIN ENTRANCE OFF BEACH RD
05:23:35	Duplicate Event:Location = 40 BEACH RD,AUCKLAND CENTRAL,AUCKLAND: #118503, Type
05:23:35	= SPRNKLR - SPRINKLER INVESTIGATION, Caller Name = ELECTRA SERVICES LIMITED,
05:23:35	INC INFO: ALARM ACTIVATION - COMMERCIAL
05:23:35	Caller Ph Number = [REDACTED], Caller Address = 290 OXFORD STREET, LEVIN,
05:23:35	HOROWHENUA DISTRICTInc InfoALARM ACTIVATION - COMMERCIAL, Event Source = Fire
05:23:35	111
05:23:35	End of Duplicate Event data
05:29:04	Unit PARN255 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
05:39:54	Unit AUCK207 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
05:44:46	Unit GREY261 [ K3 : ON RT OUTSIDE NORMAL TURNOUT AREA]
05:44:51	Unit PARN251 [ KC : UNIT CALLING]
05:45:21	Unit PARN251 [ K47 : STOP MESSAGE: MESSAGE UNCHANGED FROM INFORMATIVE]
05:46:12	Unit PARN251 [ K4 : ON RT INSIDE NORMAL TURNOUT AREA]
06:09:09	** Assigned Result Code: STRU, Detailed Event Type: 1100, Qualifier 1: Q1,
06:09:09	Qualifier 2:

**Incident**

<b>CAD Number</b>	F2346657
<b>Incident Reporter</b>	Craig Lampp
<b>Incident Controller</b>	SO Lampp
<b>Distance Travelled (km)</b>	
<b>Delay In Receiving Call</b>	

**Property Details**

<b>Occupant</b>	Unknown
-----------------	---------

**Building Owner** Unknown  
**General Property Use** Hotel, Motel, Lodge, Timeshare  
**Special Property Use** Hotel, Motel, Lodge: With liquor licence  
**Purpose Group**

**Actions**

**Persons Reported Trapped** No  
**Evacuation Status** Evacuation in progress  
**Action Prior 1** No action taken by Civilian/Occupant/Passerby  
**Action Prior 2**  
**Action Taken** Extinguishment and ventilation

**Civilians**

**Civilians Rescued** 0  
**Civilians Extricated** 0  
**Civilians Assisted** 0  
**Civilians Evacuated**

**Origin**

**Location** Laundry area, Wash house  
**Level** Ground level

**Equipment Used**

Quantity	Equipment
1	Hose reel, high pressure delivery
1	Thermal Imaging Camera
4	BA set
1	PPV - Passive Use (eg. Ventilation/Salvage)
2	Hand tools - Crowbar, Saw, Hammer, Mop, Broom, Misc small gear
14	Handheld Radio (or Cellphone)

**Equipment Involved**

**Equipment Involved**  
**Year**  
**Make** speed queen  
**Model** les37awf43

**Fire**

**Arrival Condition** Small fire

**Heat Source** Spontaneous ignition, Organic reaction (hay, linseed oil)  
**Termination Stage** Overheat  
**First Object Ignited** Linen eg. Towels, Tablecloths (NOT Bedding)  
**First Object Material** Fabric, Fibre (finished)  
**Second Object Ignited**  
**Second Object Material**  
**Indicated Cause** Pyrophoric  
**Certainty of Cause** High  
**Age of Person** Persons: 17 - 64 yrs  
**Ethnicity** European/Pakeha  
**Gender** Female  
**FAIP Service Offered** No **FAIP Service Accepted** No

**Alarms**

Type of Alarm Initiating Call Smoke Detector System (Monitored)  
Performance of System Alerted occupants - detector not in room of origin  
Failure/Ineffectiveness of system  
Number of sprinkler heads operated

**Comments**

7/20/2017 7:46:10 PM

Reporter Comments

Speed Queen  
Model #les37awf4350  
Serial # 1306034824

Craig Lampp